



ଅଧିକ୍ଷକମନ୍ତ୍ରୀଙ୍କକାର୍ଯ୍ୟାଳୟ
ଗ୍ରାମ୍ୟଜଳଯତ୍ନ-ଗାଣପତିମଳଖଣ୍ଡବଳାଙ୍ଗିର
OFFICE OF THE EXECUTIVE ENGINEER
RURAL WATER SUPPLY & SANITATION DIVISION
BALANGIR

Near R.T.O. Office
Balangir, Odisha-, Pin-767001

☎-06652-232173 (Off)

Email: eerwss_blg@nic.in

Email: eerwssbalangir@gmail.com

Letter No. 778 dt. 18-2-26

To

The Principal OAV Bibina

Balangir

Sub: - Submission of water Sample test report.


Sir,

With reference to above cited subject cited above, please find enclosed the water sample test report conducted at the District Water testing Laboratory, Balangir. The Water sample was collected from the designated source by your authorized personnel, and the analysis has been carried out based on the submitted sample

The detailed test results as per the analysis conducted, are attached herewith in Annexure-A for your reference and necessary action.

Encl: - As above.

Yours Faithfully,


17-02-26
Executive Engineer
RWS&S Division, Balangir

17-02-26

Memo

Date

Copy submitted to

1. The Additional Chief Engineer, Balangir for Information and necessary action
2. In-charge, State NABL Lab, RWS&S, Khandagiri, Bhubaneswar
3. The Chief Engineer, RWS&S Bhubaneswar, Odisha for information and necessary action.

Analysis Results

Sl. No.	Block	Gp	Village	Location	Parameter	Unit	Test Method	Result	Permissible Limit (IS: 10500-2012)	Remarks
1	Saintala	Saintala	Bibina	OAV Bibina	pH	-	IS 3025 (Part 11):1983	7.2	8.5	
					Total Dissolved Solids (TDS)	mg/L	IS 3025 (Part 16):1984	210	2000	
					Turbidity	NTU	IS 3025 (Part 10):1984	0.12	5	
					Chloride (Cl ⁻)	mg/L	IS 3025 (Part 32):1988	20	1000	
					Fluoride (F ⁻)	mg/L	IS 3025 (Part 23):1986	0.2	1.5	
					Total Hardness as CaCO ₃	mg/L	IS 3025 (Part 21):1983	46	600	
					Iron (Fe)	mg/L	IS 3025 (Part 53):2003	0.09	1	
					Alkalinity	mg/L	APHA,23rd Ed.2017-2320 B(Titration Method) 2017	46	600	

Skjoshi
17-02-2026
Lab. Assistant

Divisional Laboratory, RWS&S Balangir

U. K. K. K.
17-02-26
Lab. Chemist

Divisional Laboratory, RWS&S Balangir

[Signature]
17-02-26
Executive Engineer
RWS&S Division, Balangir

Nikan
17-02-26