

DISTRICT WATER TESTING LABORATORY, R.W.S.&S. DIVISION, KALAHANDI (ODISHA)

AT/PO-PARAMANANDPUR CHOWK, INFRONT OF OLD TVS SHOWROOM, BHAWANIPATNA

Phone No: 06670-230784; E-mail. – distlabkldrws@gmail.com



WATER ANALYSIS REPORT

TEST REPORT NO.- DWTLK-TR-123/2025-26
DATE OF ISSUE – 31.03.2026



Sample Particulars		Details of Sampling	
Name of the Customer :-	Principal, ODISHA ADARSHA VIDYALAYA, At/Po – Junagarh, Block – Junagarh, Dist-Kalahandi (Odisha).	Type of Source:-	1. Ground Water
		Date of Sampling:-	30.03.2026
		Sample receive date:- Vide letter No.	30.03.2026
sSample Package Condition:-		Sample Registration Date:-	30.03.2026
a) Quantity of Sample Received – 500ml (Each)		Sampling Protocol:-	Samples are collected by this Laboratory.
b) Type of Container - pp		Sample Collected by:-	Lab Attendant Cum Sample Collector,
		Sample Location:-	

TEST RESULT

Test Started on-		30.03.2026		Test Completed on-		31.03.2026	
Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method	
				Acceptable Limit	Permissible Limit in absence of alternate source		
1	Fluoride	mg/l	1- 1.15	1.0	1.5	Ion- Selective Electrode Method (APHA 23 rd Ed.-4500 F-C	
2	Total Coli/ E-coli	MPN/100ml	1- Absent	Shall not be detectable in any 100 ml samples.		Coliert-18/DEXX-Quantity Tray (enzyme Substrate Test)	

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory.

The test report shall not be reproduced except in full without written approval of DWTLK

#APHA – American Public Health Association

The parameters are not accredited by NABL.

Checked & compared by.

31.03.2026
 Quality Manager
 District Water Testing Laboratory,
 RWS&S Division, Kalahandi

***** End of Report*****

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 124Date: 31.03.2026

It is certified that an inspection team headed by A.E. RWS&S Section, Junagarh.
(Name of Officers with designation) from Kalahandi R. W. S & S Division, Bhawanipatna. (Name of
Department/Office) inspected the Odisha Azaosha vi2yq/aya, Junagarh.
(Name & Address of the School) on 30.3.2026 and found that the
Odisha Azaosha vi2yq/aya, Junagarh. (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per the norms prescribed by the
Central/State/U.T Govt.

The above valid for a period of: One Year.

S.S.S. Jena
31.03.2026

Lab-Chemist
District Water Testing Laboratory
Kalahandi RWS&S Division,
Bhawanipatna

Signature with Seal :

Name : Suzhanshu Sekhar JenaDesignation : Lab - ChemistTo The. PrincipalOdisha Azaosha vi2yq/ayaJunagarh, Kalahandi, Odisha.

(Name & Address of the Institution)